

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7161-1281:102 Page 1 of 1

CATEGORY: Cables-Fire Protective Signaling

LISTEE: BSCC, 233 Florence Street, Leominster, MA 01453
Contact: Paul Grant (978) 537-9138

DESIGN: Type FPLR power limited fire protective signaling cable.
Insulation - SR-PVC Compound Gitto/Global 1046 (105⁰).
Assembly of Conductors - (Two or more conductors assembled in accordance with the standard.
Jacket - PVC Compound Gitto/Global GA91-84 (75⁰)
Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 760, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type FPLR, rating and UL label.

APPROVAL: Listed as power-limited fire protective signaling cable.

06-03-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 9, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy**

